

**Sequence of System Restoration Attempt**

Time	Mahaweli System	Remarks	Laxapana System	Remarks	Samanlawewa System	Remarks	Kukule System	Remarks
12:30	Failure occurred							
12:57	Victorai unit 02	Resumed	New Laxapana unit 01	Resumed				
13:10	Victorai unit 02	Tripped						
13:21	Victorai unit 01	Resumed	New Laxapana unit 01	Tripped				
13:27	Victorai unit 01	Tripped						
13:29					Samanalawewa unit 01	Resumed		
13:33	Victorai unit 01	Resumed						
13:36	Victorai unit 01	Tripped						
13:36	Kotmale unit 03	Resumed						
13:43			New Laxapana unit 02	Resumed				
13:46					Samanalawewa unit 01	Tripped		
14:00	Kotmale unit 02	Resumed						
14:05	Kotmale unit 02/ 03	Tripped						
14:06			New Laxapana unit 02	Tripped				
14:14			New Laxapana unit 01	Resumed				
14:19	Kotmale unit 01	Resumed						
14:30					Samanalawewa unit 01	Resumed		
14:41			New Laxapana unit 01	Tripped				
14:42					Samanalawewa unit 01	Tripped		
14:49							Kukule unit 01	Resumed
14:51			New Laxapana unit 02	Resumed				
14:54	Kotmale unit 02	Resumed						
15:02					Samanalawewa unit 01	Resumed		
15:03							Kukule unit 01	Shutdown

15:10					Samanalawewa unit 01	Tripped			
15:16			New Laxapana unit 02	Tripped					
15:17							Kukule unit 01	Resumed	
15:32	Kotmale unit 01/ 02	Tripped					Kukule unit 01	Tripped	
15:37					Samanalawewa unit 01	Resumed			
15:42	Kotmale unit 03	Resumed			<b>Samanlawewa System Stabilized</b>				
15:49			New Laxapana unit 01	Resumed					
15:52	Kotmale unit 03	Tripped							
16:12	Kotmale unit 01	Resumed							
16:19								Kukule unit 01	Resumed
16:21			New Laxapana unit 01	Tripped					
16:33			New Laxapana unit 01	Resumed					
16:52			New Laxapana unit 01	Tripped					
17:04	Kotmale unit 02	Resumed							
17:35								Kukule unit 02	Resumed
18:01	Kotmale unit 03	Resumed					<b>Kukule System Stabilized</b>		
	<b>Mahaweli System Stabilized</b>								
18:08	<b>Samanalawewa System &amp; Kukule System synchronized via Ambalangoda- New Galle 132kV circuit 01</b>								
	<b>Mahaweli System Stabilized</b>	<b>379 MW</b>			<b>Samanalawewa + Kukule System Stabilized</b>			<b>205 MW</b>	
18:46	<b>Mahaweli System &amp; Samanalawewa System Syncnoized via New Laxapana- Polpitiya 132kV circuit 1</b>								
18:47	<b>Single System - 584 MW</b>								